

Nominal Wall Thickness

AWG#		SINGLES	JACKET	
22		.007	.013	
24		.007	.013	

Construction:
**MANUFACTURED IN
ACCORDANCE WITH
(UL) NEC ARTICLE
800 TYPE CMR.
FOUR
CONDUCTORS OF
SOLID BARE
COPPER
INSULATED WITH
PVC, EXTRUDED
WITH A BEIGE
JACKET OF .015"
COLOR CODE IS
RED, BLACK,
GREEN AND
YELLOW.**

**504 Silver Street Manchester, NH 03103
Phone (603) 624-2427 Fax (603) 641-9296**